



- GENERAL NOTES:**
1. ALL GARAGES SHALL RECEIVE 1 LAYER OF 5/8" THICK TYPE X GWB ON THE WALLS WHICH BORDER LIVING SPACES
 2. SMOKE DETECTORS SHALL BE LOCATED IN ACCORDANCE w/ PRESCRIPTIVE CODE REQUIREMENTS
 3. FOUNDATION SIZES, POSTS, AND BEAMS SHALL BE IN ACCORDANCE w/ VUSBC, IBC 2006 EDITION DESIGN CHARTS
 4. BUILDING SHALL MEET ENERGY CONSERVATION REQUIREMENTS BY COMPLYING w/ THE VUSBC PRESCRIPTIVE REQUIREMENTS
 5. ALL EXTERIOR WALLS SHOWN AS 6" THICK & ALL INTERIOR WALLS SHOWN AS 4 1/2" THICK U.N.O.